

Implementation of the Large Combustion Plant BAT Conclusions – A Perspective from the European Turbine Network

Executive Summary

Introduction

The European Turbine Network (ETN) is a non-profit membership association, which brings together the entire value chain of the stationary gas turbine technology (power generation and mechanical drive) community in Europe and beyond. We represent users of large Gas Turbine (GT) plant in the utility, process and Exploration and Production sectors as well as research groups, manufacturers and service providers. Our membership currently counts 99 organisations.

ETN is a member of the Article 13 Forum, and LCP BREF Revision Technical Working Group and has been actively engaged in the development of the revised Large Combustion Plant Best Available Techniques Reference (LCP BREF) document. This paper has been produced to assist Competent Authorities in interpreting some of the BAT conclusions as they relate to GT plant. Correct interpretation of these is important as these BAT Conclusions are mandatory under the Industrial Emissions Directive. This paper is based on the publically available documentation from the LCP BREF Authors and the European Commission, as well as the information captured by the ETN delegation during the revision process.

Potential to Derogate from BAT

The Industrial Emissions Directive clearly sets the back stop emissions for GT plant and mandates the implementation of BAT. However, in Article 15(4) it does also foresee derogation from BAT where;

...an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

- (a) the geographical location or the local environmental conditions of the installation concerned; or*
- (b) the technical characteristics of the installation concerned.*

This is justified as, "the competent authority shall in any case ensure that no significant pollution is caused and that a high level of protection of the environment as a whole is achieved."

Furthermore, the BAT conclusions do not apply to LCPs subject to the specific derogations in Articles 32 to 25 (Transitional National Plant, Limited Life Derogation, Small Isolated Systems and District Heating Plants respectively). This is clarified in an FAQ clarification by the European Commission¹.

Background to Gas Turbine Technology [taken from website, some changes]

To convert different fuel sources to electricity, gas turbines play an indispensable role. Furthermore, forecasts of world power demand predict a substantial increase over the next 25 years [*is there a ref for this?*].

¹ <http://ec.europa.eu/environment/industry/stationary/ied/faq.htm>

It is also widely accepted that fossil fuels will still be the dominant fuel for power generation in 2030, in Europe and globally. In addition, power generation from renewables such as biomass, biogas and syngas is gaining importance in energy consumption. Their fast, and responsive nature, also means that they can play an extensive role in underpinning the roll out of intermittent renewables such as wind and solar providing turndown where renewable output is high, but also large capacity generation on cold, windless days where society needs it most.

Major improvements and innovation breakthroughs in gas turbine technology will pave the way towards zero emission power generation. There is similar potential for improvement in the application of gas turbine power for mechanical drive in the production and delivery of fossil fuels: However, it is critical that the imposition of environmental regulation does not stifle this pathway towards zero emissions from the power sector. BAT Associated Emission Levels (BAT AELs) in particular have the potential to block pathways and lock in higher carbon existing generation types.

LCP BREF Interpretation Points

BAT AELs for New Combined Cycle Gas Turbines

The BAT conclusions set NO_x AELs of 10-30mg/Nm³ and 15-40 mg/Nm³ and annual and daily averages respectively. There is also some flexibility to increase the upper end of these ranges as shown below;

$$NO_x AEL_2 = NO_x AEL_1 \times \left(\frac{Actual Efficiency}{55} \right)$$

Based on public domain data, guarantee performance for most new build GT plant is 50 mg/Nm³ NO_x (offered by GE², Siemens³, Mitsubishi⁴). Operators should not be forced to buy plant at their own risk when they cannot be in receipt of a warranty. Hence AELs of 50 mg/Nm³ NO_x should be retained for natural gas fire plant. This will encourage H Class and higher technology (where higher GT combustion temperatures are used to increase efficiency and reduce CO₂ emissions, but at the expense of NO_x) deployment in Europe. It is also critical to remember that, even where good emissions performance is achieved in early operation, emission limits should be set that take into account the natural variation in performance as equipment degrades between major outages.

This challenge can be addressed through application of derogation under Article 15(4) of the IED. This is as alternatives, such as lower efficiency machines, or installing post combustion NO_x control, are disproportionate in terms of cost. This derogation is not applicable where local conditions, such as air quality, dictate these tighter emissions are required.

Energy Efficiency

² <https://powergen.gepower.com/products/heavy-duty-gas-turbines/9ha-gas-turbine.html>

³ <http://www.energy.siemens.com/hq/pool/hq/power-generation/gas-turbines/downloads/gas-turbines-siemens.pdf>

⁴ http://www.mhps.com/en/products/thermal_power_plant/gas_turbine/lineup/m701j.html

The LCP BREF states efficiency levels, either in electricity only or heat and electricity terms, for new and existing power plant. These are BAT AEELs (BAT Associated Energy Efficiency Levels). It is not the intention that these should be applied on an instantaneous or longer term average basis. The intention for these is that they should apply to plant based on a “name plate” efficiency, tested on first commissioning or after a major upgrade (such as repowering with new GTs). This is to ensure that plant of high efficiency is procured, but not to restrict its mode of operation. This reflects that two identical gas turbines, if operated in different market conditions, would report vastly different efficiency levels – unfairly giving the appearance that one may be better than the other and in extremes that one may not be BAT.

Definitions of Low Load Factor Plant (<500 hours and <1500 hours Operation)

During the drafting of the new version of the LCP BREF, the categorisation of peaking and emergency plant remained a topic of much discussion. To allow the drafting process to progress the Bureau decided, rather than to use “emergency” and “peaking” terms, to consider plants operating in the following categories:

- <500 hours per year
- 500-1500 hours per year
- >1500 hours per year

Definitions of Mid-Merit Plant (1500-4000 hours Operation)

Plant operating between 1500 hours per year and 4000 per year, are defined as “mid-merit” in the LCP BREF. However, in the drafting process they are considered in the same manner as base load plant and do not receive any of the flexibility available for <1500 hour plant. However, due to their relatively low load factors, and that in some cases these may be system critical and running at low loads, these may wholly appropriately be subject to relaxed AELs via a 15(4) derogation. It is important to note that this does not mean that these plants can exceed the emissions set by the IED, this still represents the safety net.

Carbon Monoxide and Indicative AELs

Whilst the LCP BREF sets AELs for the emission of NO_x from GT plant, the Carbon Monoxide emissions quoted are not AELs, and therefore these are to be considered as indicative in nature only. The supporting text for GT emissions table (10.27) notes that figures are given “as an indication” on a yearly basis. As these are now indicative in nature, they have also been set at a more challenging level than in the Directive.

Important to consider here is that, as these figures are indicative in nature and not AELs, no derogation is necessary from them. Competent Authorities can consider these CO concentrations as indicative for plant operating at high loads, and informative in nature.

Indicative AELs for <500 hours per year

The General Considerations section of the BAT Conclusions states the following, confirming that AELs are indicative only for <500 hour plant;

The BAT-AELs set out in these BAT conclusions may not apply to liquid fuel-fired and gas-fired turbines and engines for emergency use operated less than 500 h/yr, when such emergency use is not compatible with the use of BAT.

This statement is not limited to existing, or new, plant. Therefore in each case, for <500 hour per year, the Competent Authority has flexibility in the application of AELs (within the envelope stated by the IED).

Beyond this, further clarifications are provided in the BAT Conclusions, confirming that AELs do not apply to plant operating fewer than 500 hours per year. Where the conclusions table does suggest NO_x performance levels for these plants, it re-confirms that these are indicative in nature.

Daily AELs only for <1500 hours Operation

Interpretation of Effective Use of Dry Low NO_x (DLN) Firing

For Dry Low NO_x (DLN) GT firing systems the BAT AELs are stated as applying “when the DLN operation is effective”. The IED states that Emission Limit Values for GT plants apply above 70% of maximum load. ETN believe that this should also be the case for BAT AELs, as this helps deliver some parity with diluent based NO_x control (steam or water injection). Where Regulators wish to set alternative emissions limits for the ranges below 70% load down to minimum stable generation (however that is defined). These can be assessed separately, and presented separately in permits, to capture how the effectiveness of all firing systems varies across the load range.

Whilst not being the only approach to address this, the UK has implemented in its IED Compliance protocol a means to consider emission limit compliance across the load range⁵.

The Application of Selective Catalytic Reduction (SCR) for GT plant

The LCP BREF draft recognises that SCR is not applicable for plant operating fewer than 500 hours per year. It also recognises that there “may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1500 h/yr”. ETN are of the view that NO_x control by the use of DLN or diluent based firing systems is BAT for GT plant. These both work by reducing the peak flame temperatures seen in the GT combustor, and thus the thermal NO_x formed. Both DLN and diluent injection are recognised as BAT in the LCP BREF. However, the high cost of installing SCR on new plant means that the additional NO_x reduction is not justified in most cases – irrespective of whether operation is restricted to 1500 hours per year or not.

Furthermore, the catalyst used needs to be installed at a suitable location in the gas path (where the temperature is 300-400°C). For CCGTs this generally means between tube banks in the HRSG. Whilst for new plant this can be “designed in”, albeit at a price, this will not be possible for retrofitting existing plants. This lack of space renders retrofit practically impossible.

Finally, while GT plant has the capacity to provide reliable base load operation, the current energy market does not always require this. Therefore, much of the European fleet is operating for low

⁵ <http://www.energy-uk.org.uk/publication.html?task=file.download&id=5650>

numbers of hours per year, whilst holding permits for base load operation. These low operating hours, gives relatively little opportunity to achieve payback for the additional investment of SCR.

Whilst it should be demonstrating in each case, we believe there is no justification for SCR to become considered as the de facto BAT for GT plant.

Measurement Uncertainty and Monitoring

Relationship with Medium Combustion Plant Directive

There is a risk of double regulation where units that are <50MWth are either part of an aggregated large combustion plant >50MWth, or where they are regulated due to being on the same site as an LCP. In this case they should be appropriately regulated in line with the MCPD and/or the requirements of the BAT Conclusions.

Where units do form part of aggregated LCPs (these units will each by >15MWth), then BAT will apply as these are Chapter III plant (and not subject to the MCPD).

In other cases the MCPD will apply, and may require modifications to IED permits to include the monitoring requirements set in the MCPD.

Other Than Normal Operating Conditions (OTNOC)

Conclusions

Table 10.27: BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines

Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) (°) (°)	
		Yearly average (°) (°)	Daily average or average over the sampling period
Open-cycle gas turbines (OCGTs) (°)			
New OCGT	≥ 50	15–35 (°)	25–50 (°)
Existing OCGT (excluding turbines for mechanical drive applications) – All but plants operated < 500 h/yr	≥ 50	15–50	25–55 (°)
Combined-cycle gas turbines (CCGTs) (°)			
New CCGT	≥ 50	10–30 (°)	15–40 (°)
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 (°)
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 (°)	35–55 (°)
Open- and combined-cycle gas turbines			
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 (°)(°)
Existing gas turbine for mechanical drive applications – All but plants operated < 500 h/yr	≥ 50	15–50 (°)	25–55 (°)

(°) The lower end of the BAT-AEL range for NO_x can be achieved with DLN burners.

(°) These BAT-AELs also apply to the combustion of natural gas in dual-fuel-fired turbines.

(°) The higher end of the range is 80 mg/Nm³ in the case of plants which were put into operation no later than 27 November 2003 and are operated between 500 h/yr and 1500 h/yr.

(°) These BAT-AELs do not apply to existing plants operated < 1500 h/yr.

(°) These BAT-AELs do not apply to existing turbines for mechanical drive applications or to plants operated < 500 h/yr.

(°) For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the BAT-AEL range, corresponding to [higher end] x EE / 55, where EE is the net electrical efficiency of the plant determined at ISO baseload conditions.

(°) For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] x EE / 39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.

(°) Optimising the functioning of an existing technique to reduce NO_x emissions further may lead to levels of CO emissions at the higher end of the indicative range for CO emissions given after this table.

(°) For existing plants put into operation no later than 7 January 2014, the higher end of the BAT-AEL range is 65 mg/Nm³.

(°) For existing plants put into operation no later than 7 January 2014, the higher end of the BAT-AEL range is 80 mg/Nm³.

(°) For existing plants put into operation no later than 7 January 2014, the higher end of the BAT-AEL range is 55 mg/Nm³.

(°) For existing plants put into operation no later than 7 January 2014, the higher end of the BAT-AEL range is 65 mg/Nm³.

(°) For existing plants put into operation no later than 7 January 2014, the higher end of the BAT-AEL range is 60 mg/Nm³.

(°) These levels are indicative.

(°) In the case of a gas turbine equipped with DLN, these BAT-AELs apply only when the DLN operation is effective.

As an indication, the yearly average CO emission levels will generally be as follows for each type of existing combustion plant operated ≥ 1500 h/yr and for each type of new combustion plant: